



LPC Laboratories

Centre for Fire and Security Testing

Melrose Avenue, Borehamwood, Hertfordshire, WD6 2BJ

Telephone: 020 8207 2345

Facsimile: 020 8207 6305

TE 200024

TEST REPORT

Title: Large scale surface spread of flame test to B.S. 476 : Part 7 : 1997 on Gustafs BF panel system.

Client: Gustafs Inredningar I Dalarna AB,
Box 43,
S-78303 Gustafs,
Sweden.

Date: 28 July 2000



REPORT DISCLAIMERS

1. LPC warrants that the report has been prepared with all reasonable skill and care. LPC will only accept liability for deficiencies in any report caused by its breach of contract or negligence. Negligence shall be defined as in Section 1(1) of the Unfair Contract Terms Act 1977. Except in the case of death or personal injury arising from the negligence of LPC, liability of LPC for breach of contract or negligence or otherwise in relation to the preparation of the report shall in no case exceed the fee paid by the Client for the report. LPC shall in no circumstances be liable for any other loss, charges, damages, indirect or consequential loss (including loss of profit) or expenses of any kind. The Client acknowledges that all possible circumstances in which the report may have some relevance cannot be foreseen at the time the report is prepared. The Client also acknowledges that LPC would not be able to provide the Report for the agreed fee if LPC were obliged to accept all far reaching responsibilities.
2. The scope of any report produced by LPC shall be limited to matters specifically identified in the Proposal or indicated in the report. Except where LPC has otherwise agreed in writing, LPC shall not be liable for any reliance placed on a report by any person other than the Client or for any reliance placed on a report which is not specified in or envisaged by the Proposal. LPC shall not be liable for any loss caused by a report where such loss arises as a result of the provision to LPC of false, misleading or incomplete information by the Client or as a result of the act or omissions of any other person.
3. If a time-scale or similar limitation is quoted in the report, then the LPC accepts no responsibility for the validity of the information contained in the report after the stated period.
4. Any opinions which may be expressed in the report by the LPC are to be regarded as expressing the opinion only of the LPC and are not part of the factual content of the report and are outside the scope of UKAS accreditation.
5. This report may only be reproduced by the client. Any such reproduction must be in full, without comment, abridgement, alteration or addition, unless otherwise agreed in writing by the LPC.
6. This report relates only to the specimen(s) tested and does not by itself infer endorsement, approval or certification of the product(s) tested and no claim may be made to this effect based solely on this report.
7. Where reference to the UKAS accreditation or use of the UKAS logo is made in the report, then this indicates that the testing is covered by UKAS accreditation, unless otherwise indicated by a † which denotes tests or sections not UKAS accredited.



LPC Laboratories

Centre for Fire and Security Testing

Melrose Avenue, Borehamwood, Hertfordshire, WD6 2BJ

Telephone: 020 8207 2345

Facsimile: 020 8207 6305

TE 200024

SUMMARY

A sample of Gustafs BP panel system backed for the test with non-combustible board, 12mm thick, was submitted to a large scale surface spread of flame test to B.S. 476 : Part 7 : 1997 on 12 May 2000.

Class 1 was achieved.

conqueror



LPC Laboratories
Centre for Fire and Security Testing

TE 200024

Melrose Avenue, Borehamwood, Hertfordshire, WD6 2BJ
Telephone: 020 8207 2345 Facsimile: 020 8207 6305

Test and report by:

Approved by:

B. McDonald
Technical Officer

^{1P} R.A. Jones
Section Manager, Building Products

BM/MB
28 July 2000

P.J. Field
Laboratory Manager

CONQUETOR



LPC Laboratories

Centre for Fire and Security Testing

Melrose Avenue, Borehamwood, Hertfordshire, WD6 2BJ

Telephone: 020 8207 2345

Facsimile: 020 8207 6305


TE 200025

TEST REPORT

Title: Fire propagation test to B.S. 476 : Part 6 : 1989 on Gustafs BF panel system.

Client: Gustafs Inredningar I Dalarna AB,
Box 43,
S-78303 Gustafs,
Sweden.

Date: 28 July 2000

**BRE**

LPC Laboratories

Centre for Fire and Security Testing

Melrose Avenue, Borehamwood, Hertfordshire, WD6 2BJ

Telephone: 020 8207 2345

Facsimile: 020 8207 6305

TE 200025

REPORT DISCLAIMERS

1. LPC warrants that the report has been prepared with all reasonable skill and care. LPC will only accept liability for deficiencies in any report caused by its breach of contract or negligence. Negligence shall be defined as in Section 1(1) of the Unfair Contract Terms Act 1977. Except in the case of death or personal injury arising from the negligence of LPC, liability of LPC for breach of contract or negligence or otherwise in relation to the preparation of the report shall in no case exceed the fee paid by the Client for the report. LPC shall in no circumstances be liable for any other loss, charges, damages, indirect or consequential loss (including loss of profit) or expenses of any kind. The Client acknowledges that all possible circumstances in which the report may have some relevance cannot be foreseen at the time the report is prepared. The Client also acknowledges that LPC would not be able to provide the Report for the agreed fee if LPC were obliged to accept all far reaching responsibilities.
2. The scope of any report produced by LPC shall be limited to matters specifically identified in the Proposal or indicated in the report. Except where LPC has otherwise agreed in writing, LPC shall not be liable for any reliance placed on a report by any person other than the Client or for any reliance placed on a report which is not specified in or envisaged by the Proposal. LPC shall not be liable for any loss caused by a report where such loss arises as a result of the provision to LPC of false, misleading or incomplete information by the Client or as a result of the act or omissions of any other person.
3. If a time-scale or similar limitation is quoted in the report, then the LPC accepts no responsibility for the validity of the information contained in the report after the stated period.
4. Any opinions which may be expressed in the report by the LPC are to be regarded as expressing the opinion only of the LPC and are not part of the factual content of the report and are outside the scope of UKAS accreditation.
5. This report may only be reproduced by the client. Any such reproduction must be in full, without comment, abridgement, alteration or addition, unless otherwise agreed in writing by the LPC.
6. This report relates only to the specimen(s) tested and does not by itself infer endorsement, approval or certification of the product(s) tested and no claim may be made to this effect based solely on this report.
7. Where reference to the UKAS accreditation or use of the UKAS logo is made in the report, then this indicates that the testing is covered by UKAS accreditation, unless otherwise indicated by a † which denotes tests or sections not UKAS accredited.



LPC Laboratories

Centre for Fire and Security Testing

Melrose Avenue, Borehamwood, Hertfordshire, WD6 2BJ

Telephone: 020 8207 2345

Facsimile: 020 8207 6305

TE 200025

SUMMARY

A sample of Gustafs BF panel system was submitted to a fire propagation test in accordance with B.S. 476 : Part 6 : 1989 on 12 May 2000.

The material achieved a fire propagation index, I, of 6.6 comprising sub-indices i_1 of 1.1, i_2 of 3.5 and i_3 of 2.0.



LPC Laboratories

Centre for Fire and Security Testing

Melrose Avenue, Borehamwood, Hertfordshire, WD6 2BJ

Telephone: 020 8207 2345

Facsimile: 020 8207 6305

TE 200025

Test and report by:

Approved by:

Bruce McDonald

B. McDonald
Technical Officer

Richard Earle (R. EARLE)

pp R.A. Jones
Section Manager, Building Products

BM/MB
28 July 2000

P. Field

P.J. Field
Laboratory Manager

CONQUEROR